



Notes:

1. WCMES ONLY ALLOWS THE USE OF COPPER CONDUCTORS FOR SERVICE ENTRANCE
2. AN EYEBOLT MUST BE INSTALLED WHEN RISER DOES NOT GO THROUGH THE ROOF
3. RISERS TALLER THAN 36" ABOVE ROOF LINE MUST BE ANCHORED
4. SMOKE DETECTORS WILL BE REQUIRED INSIDE THE DWELLING
5. ALL WIRING MUST BE DONE IN ACCORDANCE TO NEC SPECIFICATIONS



WCMES
OVERHEAD SERVICE
DIAGRAM